


THE CORPORATION FOR THE CITY OF THOROLD



**CITY HALL RENOVATIONS CONSTRUCTION
CONTRACT NO. 602CH0003**

ADDENDUM NO. 2

Addendum Date Issued: March 13, 2019

Closing Date and Time: Thursday March 26, 2020 at 2:00 PM

1. Directive

This addendum shall form an integral part of the Form of Tender for the above contract and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements of the previously issued documentation with which it may prove to be at variance, unless otherwise clarified by the Project Manager.

This addendum must be signed by the Proponent in the appropriate space and included at the time of submission. Proposals not including this signed addendum as requested may be rejected as informal.

2. Modifications:

i) N/A

3. Questions and Answers

| | |
|--------------------|---|
| Question 1: | Demolition – There is nothing on the demolition drawing to indicate any existing electrical or data to be removed. Not sure how to a lot time for this. |
| Answer 1: | Existing power and data to remain except as noted |
| Question 2: | Lighting – Is lighting being affected in any way? |
| Answer 2: | No changes to existing lighting |
| Question 3: | Systems Furniture – Is Division 26 only required to power the whips or layout devices within as well? |
| Answer 3: | Yes, you are just to provide the Whip/power pole, the system furniture to handle the wiring in the work stations. |
| Question 4: | Data Locations located outside of demolition area, are these existing (displayed for reference) or new? For example areas like: 1. Council Chambers 2. Committee Rooms 3. Various offices 4. Various doors and ceiling mounted devices |
| Answer 4: | 1. 1 new ceiling mounted AV and 1 new Ceiling WIFI 2. 1 new AV wall mounted in Committee #1 and #2 3. Existing to remain 4. Existing to remain outside of the new office areas. |

Issued By Curtis Dray
 Manager, of Community Services

Proponents Signature: _____

Date: _____